


Company name would be located here

Chlorination Report Sample

To Whom It May Concern,

performed water sterilization at 521 N. Tangerine Rd Oro Valley Az. All new water piping was isolated and injected with chlorine at a rate of 50 ppm. We then purged all water outlets until full of chlorinated water and left to stand for 24 hours. All water was then purged until chlorine was no longer present. At that time a sample was provided to Labs for testing. Any questions or concerns please contact Department Manager 520-



May 14, 2020



Tucson, AZ 85713

TEL (520) [Redacted]
FAX

RE: Drinking Water

Work Order No.: [Redacted]
Order Name: O.V.H. G.I.

Dear [Redacted],

[Redacted] Laboratories, Inc. received 1 sample(s) on 05/13/2020 for the analyses presented in the following report.

All results are intended to be considered in their entirety, and [Redacted] Laboratories, Inc. is not responsible for use of less than the complete report. Results apply only to the samples analyzed. Samples will be disposed of 30 days after issue of our report unless special arrangements are made.

The pages that follow may contain sensitive, privileged or confidential information intended solely for the addressee named above. If you receive this message and are not the agent or employee of the addressee, this communication has been sent in error. Please do not disseminate or copy any of the attached and notify the sender immediately by telephone. Please also return the attached sheet(s) to the sender by mail.

Please call if you have any questions.

Respectfully submitted,

[Redacted] Laboratories, Inc.
ADHS License A [Redacted]



Project Manager



Client: ██████████
Project: Drinking Water
Work Order: 20E0303
Date Received: 05/13/2020

Order: O.V.H. G.I.

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Matrix	Collection Date/Time
20E0303-01	1521 N. Tangerine	Drinking Water	05/13/2020 0800

SECTION 610 DISINFECTION OF POTABLE WATER SYSTEM

610.1 General. New potable water systems shall be purged of deleterious matter and disinfected prior to utilization. The method to be followed shall be that prescribed by the health authority or water purveyor having jurisdiction or, in the absence of a prescribed method, the procedure described in either AWWA C651 or AWWA C652, or as described in this section. This requirement shall apply to “on-site” or “in-plant” fabrication of a system or to a modular portion of a system.

1. The pipe system shall be flushed with clean, potable water until dirty water does not appear at the points of outlet.
2. The system or part thereof shall be filled with a water/chlorine solution containing not less than 50 parts per million (50 mg/L) of chlorine, and the system or part thereof shall be valved off and allowed to stand for 24 hours; or the system or part thereof shall be filled with a water/chlorine solution containing not less than 200 parts per million (200 mg/L) of chlorine and allowed to stand for 3 hours.
3. Following the required standing time, the system shall be flushed with clean potable water until the chlorine is purged from the system.
4. The procedure shall be repeated where shown by a bacteriological examination that contamination remains present in the system.